

SOCKET UNION (COMP-003-ABS-R25 - 25mm)



EN

Used for breaking a section of aspirating smoke detection pipe network for maintenance purposes. This device is designed for aspirating fire detection only.

Installation Instructions:

Use the correct solvent Plusbond 3019. Do not paint. Keep pipe clean and free from dust. Do not install in direct sunlight. Only install with approved pipe. Do not use solvents to clean, only soapy water. Do not over tighten. Keep O'Ring in place. Ensure that the socket union locks into position when tightening.

TR

Bakım amacıyla aspirasyonlu duman algılama boru ağının bir bölümünü kırmak için kullanılır. Bu cihaz sadece aspirasyonlu yangın algılama için tasarlanmıştır.

Kurulum Talimatları:

Doğru solvent Plusbond 3019 kullanın. Boya yapmayın. Boruyu temiz ve tozsuz tutun. Doğrudan güneş ışığı altında montaj yapmayın. Sadece onaylı boru ile monte edin. Temizlemek için solvent kullanmayın, sadece sabunlu su kullanın. Aşırı sıkmayın. O'Ringi yerinde tutun. Sıkma sırasında soket rakorunun yerine kilitlendiğinden emin olun.

OPERATING TEMPERATURE:
-40°C to 70°C

DIAMETER TOLERANCE:
+/- 0.15mm

OUTSIDE DIAMETER:
31.3mm

WEIGHT:
26 Grams

PIPE COLOUR:
Red

WALL THICKNESS:
3.22mm

INSIDE DIAMETER:
25mm

