

FLUSH SAMPLING KIT (COMP-0019F-ABS-R25 - 25mm)

Compatible[®]

EN

Used when the aspirating pipework is above a suspended ceiling, the flush head is fed to the ceiling tile with the supplied nut and linked to the pipework using a two meter length of 10mm OD tubing and a capillary T piece which links into the pipe.

Installation Instructions:

Use the correct solvent Plusbond 3019. Do not paint. Keep pipe clean and free from dust. Do not install in direct sunlight. Only install with approved pipe. Do not use solvents to clean, only soapy water.

TR

Aspirasyon boru tesisatı asma tavanın üzerindeyken kullanılan flush başlığı, birlikte verilen somunla tavan döşemesine beslenir ve iki metre uzunluğunda 10 mm OD boru ve boruya bağlanan bir kılcal T parçası kullanılarak boru tesisatına bağlanır.

Kurulum Talimatları:

Doğru solvent Plusbond 3019 kullanın. Boya yapmayın. Boruyu temiz ve tozsuz tutun. Doğrudan güneş ışığı altında montaj yapmayın. Sadece onaylı boru ile monte edin. Temizlemek için solvent kullanmayın, sadece sabunlu su kullanın.

PART NO.:
COMP-0019F-BS-R25

**DIAMETER
TOLERANCE:**
+/- 0.15mm

FITTINGS COLOUR:
Red



TRUNK ADAPTOR
ABS022/25



10 MM NYLON TUBUNG
STANDARD LENGTH 2M



ABS09F/HO FLUSH HEAD
M16 Plastic NUT

